



BV LCIE  
CHINA  
Number

N° 1766AS04NCR24163

## ATTESTATION of conformity with European Directives

<i>Product:</i>	MCB
<i>Reference</i>	DZ47-63 Series
<i>Issued to</i>	CNC Electric Group Co., Ltd.
<i>Address</i>	Changcheng High-tech Industrial Zone, North Baixiang, Yueqing, Zhejiang 325603
<i>Manufacturer</i>	CNC Electric Group Co., Ltd.  Type C and B Ue=240/415V~(1P);415V~(2P;3P;4P) In = 6;10;16;20;25;32;40;50;63A Ics=Icn=3000A and 4500A; UI= 415V;Uimp=4kV Energy limit class:1(according to EN 60898-1) Grid distance = 45 mm Screw diameter of load terminal =4,9mm
<i>Technical characteristics</i>	

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60 898-1:2003+A1:2004+A11:2005 +A12:2008+A13:2012	B170015	07/04/2017

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), April 19<sup>th</sup>, 2017.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

**LCIE CHINA**  
必维欧亚电气技术咨询服务(上海)有限公司  
Version 3/2016.02.19

Building 4, No. 618, Xin Zuan Road,  
CaoHeping Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6196 7000  
Fax: +86 21 6196 7001  
Email: contact@cn.bureauveritas.com