

IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

CN24423

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Residual Current Operated Circuit Breaker

Name and address of the applicant
Nom et adresse du demandeur

Changcheng Electrical Equipment Group Co.,Ltd.

Name and address of the manufacturer
Nom et adresse du fabricantNo. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceName and address of the factory
Nome et adresse de l'usine

Changcheng Electrical Equipment Group Co.,Ltd.

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageNo. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceRatings and principal characteristics
Valeurs nominales et caractéristiques principales

Changcheng Electrical Equipment Group Co.,Ltd.

No. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceTrademark (if any)
Marque de fabrique (si elle existe)Ue:AC230V(2P),AC400V(3P+N,4P); In:16A,20A,25A,32A,40A,50A,63
A,80A,100A;IΔn:0.1A,0.3A,0.5A/AC;Ics:15kA;Icu:30kA;Type of over-c
urrent release:thermal and magnetic;Utilization category:A;Type of leak
age-current release:Electronic;IΔm:7.5kA;2P,3P+N,4P
CNCModel / Type Ref.
Ref. De type

YCM1LE-100L/2300,YCM1LE-100L/4300A,YCM1LE-100L/4300B;

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)**PUBLICATION****EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-2:2006 (4th Edition)+ amendment 1: 2009

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

C-027-CB2012CQC-042111

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2012-08-29

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0018239**