



Ref. Certif. No.

CN24306-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Residual Current Operated Circuit Breaker

Name and address of the applicant
Nom et adresse du demandeurChangcheng Electrical Equipment Group Co.,Ltd.
No. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceName and address of the manufacturer
Nom et adresse du fabricantChangcheng Electrical Equipment Group Co.,Ltd.
No. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceName and address of the factory
Nome et adresse de l'usineChangcheng Electrical Equipment Group Co.,Ltd.
No. 2-1 Bai Xiang Road, North Bai Xiang Town, YueQing City, ZheJiang
ProvinceNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principalesUe:AC230V(2P),AC400V(3P+N,4P); In:100A,125A,140A,160A,180A,200A,225A;I Δ n:0.1A,0.3A,0.5A/AC;Ics:15kA;Icu:30kA;Type of over-current release:thermal and magnetic;Utilization category:A; Type of leakcage-current release:Electronic;I Δ m:7.5kA;2P,3P+N,4P
CNCTrademark (if any)
Marque de fabrique (si elle existe)

YCM1LE-225L/2300,YCM1LE-225L/4300A,YCM1LE-225L/4300B;

Model / Type Ref.
Ref. De typeAdditional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2^{ème} page)

The original CB is CN24306, 2012-08-29. This modification is to correct misprint of applicant name and specification.

PUBLICATION**EDITION**A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60947-2:2006(4 th edition)+amendment 1:2009

As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

C-027-CB2012CQC-042112

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification**CHINA QUALITY CERTIFICATION CENTRE**

Date: 2012-12-03

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0017940**