



Ref. Certif. No.

HU-002546

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DC Miniature Circuit Breaker

Name and address of the applicant

Yueqing Feeo Electric Co., Ltd.  
1st Keaisi Road, Xiangyang Industrial Zone, Yueqing,  
Zhejiang, P. R. China

Name and address of the manufacturer

Yueqing Feeo Electric Co., Ltd.  
1st Keaisi Road, Xiangyang Industrial Zone, Yueqing,  
Zhejiang, P. R. China

Name and address of the factory

Yueqing Feeo Electric Co., Ltd.  
1st Keaisi Road, Xiangyang Industrial Zone, Yueqing,  
Zhejiang, P. R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Cat.A; 1P/2P/3P/4P; Ue= 300V/600V/900V/1200V DC;  
In= 6, 10, 16, 20, 25, 32, 40, 50, 63A; +40°C;  
Ui= Same as Ue; Uimp= 4,0kV; Icu= Ics= 6,0kA  
(see Test item particulars and General product  
information of Test Report for further details)

Trademark (if any)

FEEO

Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

FPV-63

Additional information (if necessary may also be reported on page 2)

---

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

1W181135

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com



Date: 2019-04-02

Signature:

Gabor Kassai