

Certificate of Compliance



No. 0E161227.ZGFC067

Test Report no. MICEZ-20161221-LVD, MICEZ-20161221-EMC

Certificate's
Holder:

Zhejiang Galaxy Fuse Co., Ltd.
Chang Chun Village Liushi Town Yueqing City China

Certification ECM
Mark:



Product:
Model(s):

Powder-Filled Cartridge Cylindrical Fuse

RT18-32

Rated voltage of fuse: AC380V~690V;
Rated current of fuse In: 2A, 4A, 6A, 8A, 10A, 16A, 20A, 25A, 32A;
Rated breaking capacity I1: 100kA;
Broken range type and usage category: gG;
Rated voltage for fuse support Un: AC380~690V;
Rated current of fuse support In: 32A, 1P;
Peak withstand current: 100kA

Verification to:

Standard:
EN 60898-1:2003/A1:2004

related to CE Directive(s):
2014/35/EU (Low Voltage)
2014/30/EU (Electromagnetic Compatibility)

Remark: The product(s) has been verified on a voluntary basis. The product(s) satisfies the requirements of the Certification Mark of ECM, in reference to the above listed Standard(s). The above Compliance Mark can be affixed on the product(s) accordingly to the ECM regulation about its release and its use. The regulation can be found at www.entecerma.it. This Certificate of Compliance can be checked for validity at www.entecerma.it

This verification doesn't imply assessment of the production of the product(s).

Additional information, clarification about the **CE** Marking:



We attest that a TCF for the **CE** Marking process is in place. Whereas the Manufacturer is Responsible to start the **CE Marking Certification Procedure** and to perform all the necessary activities, as required by the Directive before placing the **CE** Mark on the product(s).

Date of issue 27 December 2016

Expiry date 26 December 2021

Chief Manager
Marco Morina

Deputy Manager
Amanda Payne

Ente Certificazione Macchine Srl

Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY
 ☎ +39 051 6705141 📠 +39 051 6705156 ✉ info@entecerma.it 🌐 www.entecerma.it