

## VERIFICATION OF LVD COMPLIANCE

**Applicant:** WENZHOU LEEYEE ELECTRIC CO., LTD.  
**Address of applicant:** NO.1 XINGYE ROAD, DAGANG, BEIBAIXIANG TOWN, YUEQING, ZHEJIANG 325603 CHINA  
**Manufacturer:** WENZHOU LEEYEE ELECTRIC CO., LTD.  
NO.1 XINGYE ROAD, DAGANG, BEIBAIXIANG TOWN, YUEQING, ZHEJIANG 325603 CHINA  
**Product Description:** Surge Protective Device (Surge Protector)  
**Model No.:** LY1, LY2, LY3, LY7, LY8, LY9, LY10, LY21, LY22, LY23, Series  
**Rating:** In:5kA, 10kA, 15kA, 20kA, 25kA, 30kA, 40kA, 50kA, 60kA, 100kA (8/20 $\mu$ s);  
Iimp:5kA, 6.25kA, 7kA, 12.5kA, 15kA, 25kA, 50kA (10/350 $\mu$ s);  
Uc:120V, 140V, 240V, 275V, 320V, 385V, 400V, 420V, 440V, 690V  
AC; 6V, 12V, 30V, 60V, 500V, 600V, 800V, 1000V, 1200V, 1500V, 1800V DC;  
Model:1P, 1+NPE, 2P, 3P, 3+NPE, 4P.


Sufficient samples of the product have been tested and found to be in conformity with  
**Test Standard:** EN 61643-11:2012+A11:2018

As shown in the  
**Test Report Number(s):** TLZJ21022529302  
**Date of issue:** February 26<sup>th</sup>, 2021  
**Date of expiry:** February 25<sup>th</sup>, 2026

### Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher



For and on behalf of  
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd  
E-mail:info@gts-lab.com <http://www.gts-lab.com>  
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.