



Product Service

CERTIFICATE

No. B 17 04 99241 001

Holder of Certificate: Newsun PV Technology Co.,Ltd

12A, 168 Building
 Henggangtou Industrial Zone
 Xin'an Community, Chang'an Town
 523883 Dongguan City, Guangdong Province
 PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): 99241



Certification Mark:



Product: Connector
 (Connectors for Photovoltaic System)

Model(s): 4C4000, 4C4001, 4P4000, 4P4001, 4B0000, 4B0001

Parameters:

Rated Voltage:	1000 V d.c.
Rated Current:	30 A
Protection Class:	II
Degree of Protection:	IP67
Ambient Temperature:	-40 °C to +85 °C

Tested according to: IEC 62852(ed.1)
 EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64290170020701

Valid until: 2022-04-17

Harry Shubo Zhang
 (Harry Shubo Zhang)

Date, 2017-04-19
 Page 1 of 1

