



Product Service

## Attestation of Conformity

No. N8 12 09 82234 002

**Holder of Certificate:** YUEQING XINCHI ELECTRIC & SCIENCE TECHNOLOGY CO.,LTD.

MALUJIAO Village, NORTH BAIXIANG  
325003 YUEQING, ZHEJIANG  
PEOPLE'S REPUBLIC OF CHINA

**Product:** Molded case circuit breakers

**Model(s):** SL7-63C6, SL7-63C10, SL7-63C16,  
SL7-63C20, SL7-63C25, SL7-63C32,  
SL7-63C40, SL7-63C50, SL7-63C63

<b>Parameters:</b>	Rated voltage:	AC250V (1P), AC415V(2P), DC440V (2P in series), DC550V (3P in series), DC800V (4P in series), DC1000V (4P in series), DC1200V (4P in series)
	Rated frequency:	50Hz only for AC
	Rated current:	6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
	Poles No.:	1P, 2P, 4P
	Degree of protection:	IP20
	Product information:	U <sub>i</sub> = AC500V for AC, 1200V for DC U <sub>imp</sub> = 4kV Cat. A Ics =4.5kV Icu=6kV

**Tested according to:** EN 60947-2:2006

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 7041012106301-00



**Date:** 2012-09-05

(in 2nd)



After preparation of the Necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1